

## **Appendix 11. Certified Test Report**



# CERTIFIED TEST REPORT

CUSTOMER: MCCALLS METER SALES SERVICE  
MODEL NO: M0306  
METER SERIAL NO: 11-04485

## CONFIGURATION

METER INSIDE DIAMETER: 6.065  
METER OUTSIDE DIAMETER: 6.625  
TEST DATE: 6/16/2011  
TEST FACILITY: Volumetric  
IDEAL TEST CONSTANT: 6738

## CALIBRATION DATA

	Tested TC	GPM	Accuracy
1	6741	1257	100.0

CERTIFIED BY: Paul Hobbs DATE: 6/20/2011

This calibration was performed on a gravimetric or volumetric test facility, traceable to the National Institute of Standards and Technology, USA. The estimated flow measurement uncertainty of the calibration facilities are:  
Gravimetric +/- 0.15% Volumetric +/- 0.5%



3255 WEST STETSON AVENUE  
HEMET, CA 92646 USA  
PHONE (951) 652-6811 / FAX (951) 652-3078  
WEB SITE: <http://www.mccrometer.com> E-MAIL: [info@mccrometer.com](mailto:info@mccrometer.com)



11-04485

6/20/2011 9:06:38 AM  
Version 1.2 (4/18/2007)